

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 408Dated: 23/07/2026

It is certified that an inspection team headed by Mr. R.K. Tripathi Assistant Engineer
(Name of Officers with designation) from P.H.E.D. SATNA, MP PHED inspected the **SETH ANANDRAM
JAIPURIA SCHOOL, BEHIND SIDDHI VINAYAK TEMPLE, HATI ROAD, KOTHI ROAD, SATNA DIST. - SATNA,
MP** on 20/07/26 and on the basis of Water Test Report (Attached) bearing no. 280/20-05-26
dated 18/05/26 of **DISTRICT WATER TESTING LABORATORY P.H.E.D. SATNA, MP (PHED Lab)**
certified that the **SETH ANANDRAM JAIPURIA SCHOOL, BEHIND SIDDHI VINAYAK TEMPLE, HATI ROAD,
KOTHI ROAD, SATNA DIST. - SATNA, MP** has safe drinking water facilities for the students and members of
staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

[Signature]
Assistant Engineer
P.H.E. Sub Division
Satna (M.P.)

Signature with seal

:-

Name

:- Mr. R.K. Tripathi

Designation

:- Assistant Engineer

Name & address of the office/Department: - P.H.E. Sub-division Satna
Satna District - Satna (M.P.)

To,
**SETH ANANDRAM JAIPURIA SCHOOL,
BEHIND SIDDHI VINAYAK TEMPLE,
HATI ROAD, KOTHI ROAD, SATNA DIST. - SATNA, MP**
(Name and address of the institution)

[Signature]
School Manager

**Seth Anandram Jaipuria School
Satna (M.P.) 485001**

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

[Signature]
Principal
Seth Anandram Jaipuria School
Behind Siddhi Vinayak Temple, Hati Road
Satna (M.P.) Pin-485001

कार्यालय सहायक यंत्री लोक स्वास्थ्य यांत्रिकी उपखण्ड सतना(म.प्र.)

aephesat@gmail.com

क्रं 280 / लैब / स.यं. / लो.स्वा.या. / उपखण्ड-सतना / 2026

दिनांक 20/05/26

प्रति,

✓ सेठ आनंदराम

जैपुरिया स्कूल सिद्धि विनायक मंदिर के पीछे
कोठी रोड सतना जिला सतना (म.प्र.)

विषय:- जल परीक्षण के संबंध में।

संदर्भ:- आपका आवेदन पत्र क्रं 00 दिनांक 08/05/2026

उपरोक्त विषयान्तर्गत लेख है कि सेठ आनंदराम जैपुरिया स्कूल सतना जिला सतना (म.प्र.) द्वारा 01 नग वाटर सेम्पल परीक्षण हेतु प्रदाय किया गया था जिसका परीक्षण कर जल परीक्षण रिपोर्ट आपकी ओर प्रेषित है।

संलग्न:- जल परीक्षण रिपोर्ट 01 नग



सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी उपखण्ड
सतना (म.प्र.)

पृ.क्र. / लैब / स.यं. / लो.स्वा.या. / उपखण्ड-सतना / 2026

दिनांक

प्रतिलिपि:-

कार्यपालन यंत्री, लोक स्वास्थ्य यांत्रिकी खण्ड सतना की ओर सूचनार्थ।


सहायक यंत्री,
लोक स्वास्थ्य यांत्रिकी उपखण्ड
सतना (म.प्र.)


Principal

Seth Anandram Jaipuria School
Behind Siddhi Vinayak Temple, Hati Road
Satna (M.P.) Pin-485001


School Manager
Seth Anandram Jaipuria School
Satna (M.P.) 485001

DISTRICT WATER TESTING LABORATORY P.H.E.D. SATNA (M.P.)

BIS 10500:2012, Reaffirmed in feb 2021

Indian Standard DRINKING WATER – SPECIFICATION

Test characteristics for routine drinking water parameters

Sample from:- SETH ANANDRAM JAIPURIA SCHOOL SATNA (M.P.)					Received at LAB :- 18/05/2026	
Date of Collection :- 18/05/2026			Type of Sample :- Drinking Water		Date of Analysis :- 18/05/2026	
Sample Detail :-						
Sample.No.	District	Block	Habitation		Location	
1	Satna	Satna	Behind Siddhi Vinayak Temple Kothi Road		Seth Anandram Jaipuriya school Satna	
Sample Collected By :- Seth Anandram Jaipuriya school Satna						
S.No	Characteristic	Desirable Limit	Permissible limit in absence of alternate source	Sample No.1	Remark	
	<u>PHYSICAL TESTS:-</u>					
1	Taste	Unobjectionable	-----	-		
2	Odour	Unobjectionable	-----	Unobjectionable		
3	Turbidity, NTU,	1.0	5.0	1.0		
4	<u>CHEMICAL TESTS :-</u> PH value ph scale,	6.5 to 8.5	No relaxation	7.63		
5	Arsenic mg/l	0.01	No relaxation	0.0		
6	Colour hzn	5	15	5.0		
7	Total Alkalinity mg/l,	200	600	60.0		
8	Iron (as Fe) mg/l,	1.0	No relaxation	0.0		
9	Chlorides (as Cl) mg/l,	250	1000	33.93		
10	Total Hardness (as CaCO ₃) mg/l,	200	600	86.0		
11	Calcium (as Ca) mg/l,	75	200	-		
12	Magnesium (as Mg),mg/l.	30	100	-		
13	Total Dissolved solids, mg/l,	500	2000	108.0		
14	Manganese (as Mn) mg/l,	0.1	0.3	0.0		
15	Sulphate (as SO ₄) mg/l,	200	400	3.12		
16	Nitrate (as NO ₃) mg/l,	45	45	-		
17	Fluoride (as F) mg/l,	1.0	1.5	0.0		
18	Residual, free Chlorine, mg/l, <u>BACTERIOLOGICAL TESTS :-</u>	0.2	1.0	-		
19	E- Coli per 100 ml	Nil	-----	0.0		
20	Total Coliform per 100 ml	Nil	-----	0.0		

Note :- samples will be stored for a period of 10 days from the date of issue of report.


Chemist
P.H.E. Sub- Division Satna
Dist. Satna (M.P.)


Principal
Seth Anandram Jaipuriya School
Behind Siddhi Vinayak Temple, Hati Road
Satna (M.P.) Pin-485001


Assistant Engineer
P.H.E. Sub- Division Satna
Dist. Satna (M.P.)

School Manager
Seth Anandram Jaipuriya School
Satna (M.P.) 485001